

Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory Ambala Cantt. 133001
Email id: chemist.ambala@gmail.com

Test Report

Lab. ID. No. : AMB /01095/4/2024/387


Memo No: 1022

Report Issue Date: 06/05/24

S. No.	Parameter	Method Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	APHA2120 B	<5	5 HU	15 HU	HU
2	Iron as Fe	APHA 3500 Fe B	0.01	1.0	No Relaxation	Mg/l
3	Sulphate (as SO ₄)	APHA 4500 So ₄	14	200	400	Mg/l

- I. The results given above are related to the sample as received and tested in PHED Lab, Ambala Cantt. Reliability of sample lies with the sender/collector.
- II. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- III. The test report can't be used for any publicity or any legal purpose.
- IV. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.
- V. Sample has not been collected by this lab

Sample analyzed by: Vikram (Water Analyst)


(Arpana Choudhary)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Ambala Cantt.


Principal
Convent of Jesus & Mary
121, Staff Road,
Ambala Cantt.-133001



TC-11985

GOVT OF HARYANA
PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, AMBALA CANTT - 133001
E-mail:-chemist.ambala@gmail.com

**Test Report**

Lab. ID. No : AMB /01095/4/ 2024/387

Memo No : 1022

Report Issue Date: 06/05/24

ISSUED TO : PRINCIPAL CONVENT OF JESUS & MARY 121, STAFF ROAD, AMBALA CANTT-133001	Date of Analysis started : 02/05/2024 Dated of analysis completed : 02/05/2024 Temperature : 26.4 °C Humidity : 50% RH Sample Quantity : 1 Lt.
Sample Description & Type of analysis : Water (Chemical Analysis) Customer Reference No. & Date : NIL - 01/05/2024 Customer Name Who collected sample : RAJESH Sample collected on dated : 01/05/2024 Sample received on dated : 01/05/2024	Source of Sample : GOVT. WATER SUPPLY AT CONVENT OF JESUS & MARY SCHOOL

RESULTS

S. No.	Parameter	Method Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solid ^{180 °C}	APHA2540 C	80	500	2000	mg/l
2	Total Hardness	APHA2340 C	4.95	200	600	mg/l
3	Calcium (as Ca)	APHA3500-Ca B	1.98	75	200	mg/l
4	Magnesium (as Mg)	APHA3500 Mg B	0.00	30	100	mg/l
5	Total Alkalinity	APHA 2320 B	33.25	200	600	mg/l
6	Chloride (as Cl)	APHA 4500 Cl B	29.13	250	1000	mg/l
7	Fluoride (as F)	APHA 4500- F C	0.1	1.0	1.5	mg/l
8	pH @ 25 °C	APHA4500-H ⁺ B	7.24	6.5 to 8.5	No relaxation	pH Units
9	Nitrate (as NO ₃)	APHA4500-NO ₃ D	1	45	45	Mg/l
10	Turbidity	APHA 2130 B	0.29	1 NTU	5 NTU	NTU
11	Taste	IS : 3025 PART 8	Agreeable	Agreeable	Agreeable	-----
12	Odour	IS : 3025 PART 5	Agreeable	Agreeable	Agreeable	-----

- The results given above are related to the sample as received and tested in PHED Lab, Ambala Cantt. Reliability of sample lies with the sender/collector.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.
- Sample has not been collected by this lab

Sample analyzed by: Vikram (Water Analyst)

(Arpana Choudhary)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Ambala Cantt.

---End of Report---

Stellarjini
Principal
Convent of Jesus & Mary
121, Staff Road,
Ambala Cantt.-133001